

5. Outdoor public spaces


5.1.2 Curb ramps

Location:

Date and time:

Auditor:

Description:



A curb ramp with a tactile attention indicator (5.1.2.a) and a running slope between a ratio of 1:15 and 1:10 (5.1.2.b)

	Source	Yes (+ 3)	Most of the time (+ 2)	Some -times (+ 1)	No (0)	N/A (- 3)*	Comments
5.1.2.a Does the curb ramp have a tactile attention indicator before the curb ramp meets the street?	CSA B651-18 (8.3.3.4.2)						
5.1.2.b Does the curb ramp have a running slope between a ratio of 1:15 (6.66%) and 1:10 (10%)?	CSA B651-18 (8.3.3.1)						
5.1.2.c SURFACE							
5.1.2.c.i Is the surface of the curb ramp stable and firm?	CSA B651-18 (8.3.3.4)						
5.1.2.c.ii Is the surface of the curb ramp slip resistant?	CSA B651-18 (8.3.3.4)						
							<i>chart continued on next page →</i>

		Source	Yes (+ 3)	Most of the time (+ 2)	Some -times (+ 1)	No (0)	N/A (- 3)*	Comments	
5.1.2.d	Is the curb ramp aligned with the direction of travel (e.g., crosswalks) and curb ramp or depressed curb on the opposite side of the roadway?	CSA B651-18 (8.3.3)							
							Subtotal	Max. score	Actual score
							+	15	=
			Subtotal	Subtotal	Subtotal	Subtotal	Final Total		
			+	+	+	=			

Principle 1

Does this feature follow the whole journey approach?

Principle 2

Does this feature follow the concepts of universal design?

Principle 3

Is there an adequate seasonal maintenance program for this feature?