

5. Outdoor public spaces

### 5.1.3 Street crossings (crosswalks)

**Location:**

**Date and time:**

**Auditor:**

**Description:**

	Source	Yes (+ 3)	Most of the time (+ 2)	Some -times (+ 1)	No (0)	N/A (- 3)*	Comments
<b>5.1.3.a</b> Is the crosswalk at least 1800 mm (71 in.) wide between pavement markings?	CSA B651-18 (8.3.4.1)						
<b>5.1.3.b</b> Does the crosswalk include a tactile indicator where the curb slopes to the roadway?	CSA B651-18 (8.3.4.1)						

*chart continued on next page →*

	Source	Yes (+ 3)	Most of the time (+ 2)	Some -times (+ 1)	No (0)	N/A (- 3)*	Comments
<b>5.1.3.c</b>	If the intersection includes both a traffic light and sidewalk, does it employ a distinct audible indication for each discrete direction of travel?						
<b>5.1.3.d</b>	If the intersection is within a 500 m radius of a facility serving the visually impaired, does it employ a distinct audible indication for each discrete direction of travel?						
						Subtotal	Max. score
						<b>+</b>	<b>12</b>
							<b>=</b>
		Subtotal	Subtotal	Subtotal	Subtotal	<b>Final Total</b>	
		<b>+</b>	<b>+</b>	<b>+</b>	<b>=</b>		

**Principle 1**

Does this feature follow the whole journey approach?

**Principle 2**

Does this feature follow the concepts of universal design?

**Principle 3**

Is there an adequate seasonal maintenance program for this feature?