
Licensing Inspection Report (Annual Inspection)

Facility: CENTENNIAL VILLA
Address: 258 CHURCH ST.
AMHERST NS, B4H 3C9
Date(s) of Inspection: August 25, 2020

Requirements resulting from licensing inspection:

1. LTCPR 7.1.12
The licensee shall ensure required inspections of the home and equipment are completed and documentation is maintained to demonstrate compliance with requirements. These include, but are not limited to, manufacturer requirements, safety requirements, sprinkler systems, water testing, fire alarms and fuel systems.