

---

**Licensing Inspection Report ( Semi-Annual Inspection )**

Facility: DYKELAND LODGE  
Address: 124 COTTAGE ST.  
WINDSOR NS, B0N 1H0  
Date(s) of Inspection: February 13, 2020

---

**Requirements resulting from licensing inspection:**

1. LTCPR 12.1.6  
The licensee shall ensure hazardous products that may be harmful to residents are secured at all times and are not accessible to residents. They are stored and disposed of in accordance with established safety practices/manufacturers' recommendations.
2. LTCPR 12.2.2.2.c  
The licensee shall ensure aesthetic, functional and surface integrity of the following are maintained: interior building components such as, but not limited to, partitions, ceilings, doors, casework, coatings and sealants.