
Licensing Inspection Report (Annual Inspection)

Facility: FOYER PERE Fiset AUXILIARY

Address: 15092 CABOT TRAIL
CHÉTICAMP NS, B0E 1H0

Date(s) of Inspection: August 18, 2020

Requirements resulting from licensing inspection:

1. LTCPR 7.1.12
The licensee shall ensure required inspections of the home and equipment are completed and documentation is maintained to demonstrate compliance with requirements. These include, but are not limited to, manufacturer requirements, safety requirements, sprinkler systems, water testing, fire alarms and fuel systems.
2. LTCPR 7.1.12
The licensee shall ensure required inspections of the home and equipment are completed and documentation is maintained to demonstrate compliance with requirements. These include, but are not limited to, manufacturer requirements, safety requirements, sprinkler systems, water testing, fire alarms and fuel systems.
3. LTCPR 9.2.2 a
The licensee shall ensure there is a documented Business Continuity Plan that addresses the operational recovery and continuity of services in the face of a disaster, labour disruption or other major outage. The Business Continuity Plan includes the following: hazard, vulnerability and risk assessment, mission critical activities, recovery strategies, loss of electrical power, water, heat, ventilation and waste water services, loss of information technology (computer / telephone / fax) priorities, geographic footprint and pandemic situation (pandemic planning is undertaken and completed in accordance with direction received from the Department of Health and Wellness.)
4. LTCPR 11.1.3
The licensee shall ensure a written human resources plan is developed and includes the anticipated human resources required to deliver consistent, quality services.

5. HSCR 19(1)(d), LTCPR 11.1.6
The licensee shall ensure the home provides a documented, timely orientation for all staff members, volunteers and contracted personnel. The orientation provides the necessary information to support residents in a safe manner and improve their quality of life.
6. HSCR 27(7), LTCPR 9.2.4.b
The licensee shall ensure fire drills are conducted a minimum of monthly in accordance with direction from the Office of the Fire Marshal.
7. LTCPR 12.1.8
The licensee shall ensure cleaning and disinfectant products and other chemicals used in environmental cleaning are not used after their expiration date.
8. LTCPR 12.2.1.1
The licensee shall ensure there is a preventive maintenance program for the home.
9. HSCR 21
It is a term and condition of every license that the licensee shall comply with the Acts and regulations, and any orders or directions of an appropriate authority, respecting fire, safety, health and sanitary requirements.