



Safety Bulletin Number: **0000037**

Issued **Oct 24, 2024** by **Ray Grant**, Provincial Chief Electrical Inspector,
Department of Labour Skills and Immigration

Requirements for compliance to Rule 10-210 of the 2024 Canadian Electrical Code (CE Code), Part 1

Summary

The above rule provides the requirements for “grounding connections for solidly grounded AC systems supplied by the supply authority” and, along with the Appendix B notes and Figures B10-4 and B10-5, provides direction on how the grounding and bonding should occur for the consumer’s meter base and service box.

Now that the meter base standard has been revised and manufacturers can supply a meter base approved to the revised standard, implementation of the grounding and bonding methods as per the 2024 CE Code for a consumer’s meter base and service box can now be implemented.

This Bulletin replaces Bulletin 2018-03, [Electrical-Bulletin-2018-03.pdf \(novascotia.ca\)](#)

Starting October 2, 2024, a transition period will be in effect whereby this Bulletin or Bulletin 2018-03 may be used until December 31, 2024.

On January 1, 2025, Bulletin 2018-03 will no longer be an option and only 2024 CE Code Rule 10-210 will be enforced.

Contact us

Safety Branch – SafetyBranch@novascotia.ca
Labour, Skills and Immigration - 1-800-952-2687