



DIRECTIVE



Safety Directive Number: **00009**

Issued Oct 16, 2024 by Paul Fowler, Chief Inspector, Fuel Safety
Department of Labour, Skills and Immigration

Fuel Safety Directive

Legal information

Issued pursuant to section 30 of the Technical Safety Act

Summary

Provincial fuel safety inspectors are required to identify the owner or supplier of a propane container to ensure that the correct parties are notified of any safety issues or code non-compliance.

In the event of an emergency, first responders have a need to identify the owner or supplier of a propane container to ensure that they can quickly contact the appropriate parties for assistance and information related to the container(s).

Directive:

Effective January 1, 2025, all permanently installed propane containers must clearly identify the owner's or gas supplier's name and emergency contact phone number. The marking must be durable and legible, and in a visible location on the container. The owner or supplier must ensure that the marking is maintained, updated as necessary and kept in legible condition.

Contact us

Safety Branch – SafetyBranch@novascotia.ca
Labour, Skills and Immigration - 1-800-952-2687

[Fuel safety: classifications and licence requirements | novascotia.ca](#)

Issued Oct 16, 2024

Page 1 of 1