



SAFETY ALERT



Safety Alert Number: **0000001**

Issued **18 June 2020** by **Paul Fowler, Chief Inspector, Fuel Safety**, Department of Labour and Advanced Education


Gas Boiler Recall- Carbon Monoxide Hazard

Legal information

Issued pursuant to section 30(1) of the Technical Safety Act

Summary

- Please be aware that Health Canada has issued a recall notice for certain Lochinvar Condensing Gas Boilers and Condensing Gas Combi Boilers due to a carbon monoxide hazard. Please visit the Health Canada website for more information at <https://healthycanadians.gc.ca/recall-alert-rappel-avis/hc-sc/2020/72879r-eng.php>
- Consumers should stop using this equipment immediately and contact their gas supplier or service provider.
- Appliance dealers and installers should stop selling or installing this equipment immediately.





SAFETY ALERT



Contact for bulletin queries

Safety Branch

Labour and Advanced Education

1-800-952-2687

Page 1/1