



# DIRECTIVE



Safety Directive Number: **00011**

Issued **September 4, 2025** by Paul Fowler, Chief Inspector, Fuel Safety  
Department of Labour, Skills and Immigration

## Fuel Safety - Container Sizing

### Legal information

Issued pursuant to section 30 of the [Technical Safety Act](#).

### Summary

In an effort to ensure that propane installations are completed using an appropriately sized container, Fuel Safety has previously published a [table](#) listing common container sizes and their vaporization capacities. This method has resulted in some confusion around container selection and, in some cases, the need for an excessive number of containers for the type of load.

### Directive:

Effective immediately, when selecting containers for a propane installation, installers and suppliers shall determine the appropriate size and number of containers based on the information found in Annex I of the CSA B149.2 Though Annex I is listed as an informative annex, it shall be considered as mandatory with respect to the information for container sizing. This will allow flexibility in container sizing based on type of load, delivery scheduling, environmental factors, etc. This directive supersedes the requirements found in Fuel Safety Bulletin 034, published June 7, 2024.

### Contact us

Safety Branch - [SafetyBranch@novascotia.ca](mailto:SafetyBranch@novascotia.ca)  
1-800-952-2687  
Labour, Skills and Immigration

[Fuel safety: classifications and licence requirements | novascotia.ca](#) •

Issued Sept 04, 2025

Page 1 of 1