

Water Sample Results - General Chemistry and Metals

Parameter	Units	Canadian Drinking Water Guideline	Detection Limit	Sydney (050)	
				15-Sep-2005	11-Dec-2008
General Chemistry					
Total Alkalinity (Total as CaCO3)	mg/L	-	5	83	90
Chloride (Cl)	mg/L	250 AO	1	7	5
Colour	TCU	15 AO	5	ND	8
Hardness (CaCO3)	mg/L	-	-	87	89
Nitrate + Nitrite	mg/L	10	0.05	0.17	ND
Nitrite (N)	mg/L	1	0.01	ND	ND
Nitrate (N)	mg/L	10	0.05	0.17	ND
Nitrogen (Ammonia Nitrogen)	mg/L	-	0.05	ND	ND
Total Organic Carbon (C)	mg/L	-	0.5	ND	1.3
Orthophosphate (P)	mg/L	-	0.01	ND	ND
pH	pH	7.0-10.5 OG	-	8.03	7.7
Reactive Silica (SiO2)	mg/L	-	0.5	8.6	8
Sulphate (SO4)	mg/L	500 AO	2	7	7
Turbidity	NTU	-	0.1	0.3	0.2
Conductivity	uS/cm	-	-	210	190
Anion Sum	me/L	-	-	2.02	2.1
Bicarb. Alkalinity (calc. as CaCO3)	mg/L	-	1	82	90
Calculated TDS	mg/L	-	1	115	116
Carb. Alkalinity (calc. as CaCO3)	mg/L	-	1	ND	ND
Cation Sum	me/L	-	-	2.07	2.05
Ion Balance (% Difference)	%	-	-	1.29	1.2
Langelier Index (@ 20C)	N/A	-	-	0.069	-0.207
Langelier Index (@ 4C)	N/A	-	-	-0.182	-0.458
Saturation pH (@ 20C)	N/A	-	-	7.96	7.91
Saturation pH (@ 4C)	N/A	-	-	8.21	8.16
Calcium (Ca)	mg/L	-	0.1	30	31
Magnesium (Mg)	mg/L	-	0.1	3	2.8
Phosphorus (P)	mg/L	-	0.1	ND	ND
Potassium (K)	mg/L	-	0.1	1.7	1.4
Sodium (Na)	mg/L	200 AO	0.1	6.6	5.5
Bromide (Br)	mg/L	-	0.5	ND	ND
Fluoride (F)	mg/L	1.5	0.1	0.1	0.1
Metals					
Aluminum (Al)	ug/L	-	10	11	ND
Antimony (Sb)	ug/L	6	2	ND	ND
Arsenic (As)	ug/L	10	2	ND	ND
Barium (Ba)	ug/L	1000	5	93	91
Beryllium (Be)	ug/L	-	2	ND	ND
Bismuth (Bi)	ug/L	-	2	ND	ND
Boron (B)	ug/L	5000	5	15	10
Cadmium (Cd)	ug/L	5	0.3	ND	ND
Chromium (Cr)	ug/L	50	2	ND	ND
Cobalt (Co)	ug/L	-	1	ND	ND
Copper (Cu)	ug/L	1000 AO	2	7	ND
Iron (Fe)	ug/L	300 AO	50	80	250
Lead (Pb)	ug/L	10	0.5	ND	ND
Manganese (Mn)	ug/L	50 AO	2	630	830
Molybdenum (Mo)	ug/L	-	2	ND	ND
Mercury (Hg)	ug/L	1	0.01		ND
Nickel (Ni)	ug/L	-	2	ND	ND
Selenium (Se)	ug/L	50	2	ND	ND
Silver (Ag)	ug/L	-	0.5	ND	ND
Strontium (Sr)	ug/L	-	5	230	180
Thallium (Tl)	ug/L	-	0.1	ND	ND
Tin (Sn)	ug/L	-	2	ND	ND
Titanium (Ti)	ug/L	-	2	ND	ND
Uranium (U)	ug/L	20	0.1	ND	ND
Vanadium (V)	ug/L	-	2	ND	ND
Zinc (Zn)	ug/L	5000 AO	5	6	ND

Notes:

All guidelines are based on Health Canada MACs (Maximum Acceptable Concentrations) or Interim (I)MACs, unless otherwise indicated.

AO = Aesthetic Objective- see Health Canada Drinking Water Guidelines for details

OG = Operational Guidance - see Health Canada Drinking Water Guidelines for details

ND = not detected and ND() = not detected at the detection limit shown in brackets ()

"-" = not applicable

Shaded values exceed guidelines.