

APPENDIX B

Determination of distribution trench width

TABLE B1**Determination of distribution trench width in metres for C1, C2, C3 and mounds**

Length of Distribution trench pipe (m)	Flow (litres per day)		
	1000	1350 (C3/Mound Only)	1500
	Width in m	Width in m	Width in m
25	1.2	N/A	1.8
26	1.2	N/A	1.7
27	1.1	N/A	1.7
28	1.1	N/A	1.6
29	1.0	N/A	1.6
30, 31	1.0	N/A	1.5
32, 33, 34	0.9	1.2	1.4
35, 36	0.9	N/A	1.3
37, 38, 39	0.8	N/A	1.2
40	0.8	N/A	1.1
41, 42, 43	0.7	N/A	1.1
44, 45, 46	0.7	N/A	1.0
47	0.6	N/A	1.0
48 - 52	0.6	N/A	0.9
53 - 60	0.6	N/A	0.8