



TYPICAL TS-2 CONTROL CABINET FOUNDATION AND ANCHOR TEMPLATE FOR SIZE 6 AND 7 CABINETS

NOTES:
FOUNDATION:
 1. FOUNDATION FORM, ANCHOR TEMPLATE AND ANCHOR BOLTS MUST MEET NEMA TS-2 SPECIFICATIONS.
 2. GROUT ALL VOIDS TO PROVIDE SMOOTH SURFACE. FINAL SURFACE TO BE LEVEL NS AND EW. IF NOT, GROUT USING M BED, SUPERCRETE OR EQUIVALENT.
 3. SURFACE OF PAD AND FOUNDATION TO BE EDGED WITH SIDEWALK EDGER OR AS SHOWN ON PLANS.

PVC:
 1. SCHEDULE 40 TO CSA22.2 No. 211.2
 2. ALL UNUSED RUNS OF PVC ARE TO HAVE 6mm POLY ROPE PULLED THROUGH AND SECURED AT EACH END TO PREVENT PULL BACK.
 3. ALL PVC JOINTS MUST BE CLEANED (PVC CLEANER, WIPED DRY, etc.) AND CEMENTED USING PVC CEMENT.
 4. ALL FOUNDATION PVC TO EXTEND 75mm ABOVE FINISHED SURFACE.
 5. END CAP ALL PVC.
 6. SEE TRENCH DETAIL FOR PROPER CONDUIT INSTALLATION Dwg.# S-2011-094.

ROPE:
 1. 6mm POLYPROPYLENE.
 2. EACH PULL OF ROPE IS TO BE A CONTINUOUS LENGTH. DO NOT JOIN LENGTHS UNLESS IT IN A JUNCTION BOX.

CONCRETE:
 TIR STANDARD SPECIFICATION DIVISION 5 SECTION 7:
 1. 35 MPa
 2. 6% AIR ENTRAINMENT.
 3. 80mm SLUMP.

Michael CA
 Manager Traffic Engineering and Road Safety
Joseph L...
 Director Road Safety
John A...
 Executive Director Highway Engineering and Construction

1	TEXT CORRECTIONS
No.	REVISION

Scale : N.T.S.
 Drawn by : P.HILL/L.MACLEAN
 Checked by : P.HILL
 Date of Plan : APR2016
 File No. : S-2016-092