



- NOTES:
1. ALL PADLOCKS ARE TO BE MASTER No. 1 WITH KEY No. 2396.
 2. ALL PADLOCKS ARE TO BE SUPPLIED BY CONTRACTORS.
 3. RELAY ENCLOSURE - SHALL BE PART No. TCSM141007 C/W POLICE TYPE LOCK, AS SUPPLIED BY APX ENCLOSURES, OR EQUIVALENT.
 4. VOLTAGE LABELS REQUIRED ON DISCONNECT AND RELAY ENCLOSURE.

Michael P. Hill
 Manager Traffic Engineering and Road Safety

John S. Hill
 Director Road Safety

John S. Hill
 Executive Director Highway Engineering and Construction



1	LONG LIFE PHOTO CELL
No.	REVISION

Scale : N.T.S.
 Drawn by : P.HILL
 Checked by : A.THOMAS
 Date of Plan : APR2016
 File No. : S-2016-117

**TYPE A SERVICE WITH RELAY
120 VOLT HIGHWAY LIGHTING**